

Ten years of forecast use

IEA Wind Task 36 Forecasting: Workshop Barcelona directions

Sophie GUIGNARD 9 juin 2016



Maïa Eolis, branch of ENGIE

561 MW of building permits and **246 MW** currently under operation in France

1st wind farm commissioned in 2005

80 employees, most of them are engineers

230 millions euros of capital

Maïa Eolis headquarters are in Lille, We have other office in Lyon and Nantes and 3 maintenance centers based near the farms at Estrées Deniécourt (80), Rumont (55) and Méry sur Seine (10).





Our skills

Single point of contact, we manage every step of a wind farm project

Development

From site research to administrative approval

Construction

Building phase, turbines reception and end of warranty checkings



Operation

Monitoring and remote management of wind farms

e aperçu	5855	7 kW =>	234727	kW	0 kW => 0	kW		Logic	-	30673 kW =	> 234727	kW	0 kW => 0	KW	Synoptic Cover/UP1
-	1970 NW 86.8 TQ	1998 NW 66.1 TO	2814 NW 81.2 °C	1959 NW 54.9	Q 1910 NW 87.9 W			PRV	1600 107	60.8 °C 1006 kW 71.6	G 2540 kW 22.2	G 1997 NW 68	12°C 1246 HV 84.5	Q 1980 bW 72.6 %	
		=			di I	1		en i		1	03		03	0 :3	
200	1000 NW 63.3 °Q	M CO	2070 NW 87 2 TO	A	G 2015 NW - 45 3 3	0 88.7 NW 88.7 T		PRP	2010 NW	68.8 °C 1982 NW 48.8	G 1970 NW 20-4	G HARD NW . 40	M C 2031 NW 72.1	C (SEE NW. 75 A N	1
		=			di i					033	03	-	03	0 11	
	SECRETARY BEST	0048 hW 49.8 °C	1818 NW 82.3 C	**************************************	C 1910 NW 82.0 W	2044 bW 88.3 'S	1	PRS.	2017 NW	73.3 °C 3031 AW 78.8	C 1932 NV 88.3	C 1979 NW 72	1270 1316 NW 91.9	C 1979 NW 88.8 T	1
		-		-				on a		108		-	018		
	2020 NW 73.4 TC	9001 KW 62.170	2120 kW 88.0 °C	3030 kW 72.1	C 2047 NV 97.8 'S	2007 NW 78.7 'S	j	PBB	1000 KW	74.8 °C 1976 kW 73.3	C 1960 KW 87.4	1989 KW 76	1.9 °C 2001 NW 01.0	Q 1989 NW 78.1 '0	
		1 111	-	-	and the same of th	6 111				18	1	11	3 33	111	
·w A	1800 KW 80.8 °C	1200 KW \$0.0 °C		1730 AW 60.3	C 1855 W 82.3 'S		1703 NW 07.0	VM		24.8.70 (1000 KW 83.2	1994 KW 83.7		14 10 10 10 10 10 10 10 10 10 10 10 10 10		
	1			1	1	0181	6 111	and it		i i	1		6 33		
		24 LW =>	70tal	ww	0 kW => 0	.w			N ₂	ord/Picardie	> 234727	" - w	0 AW => 0	hw.	Oteure U
8	3963	, 4 kW =>	234727		0 kW => 0	kw		MP.	No.	ord/Picardie 75863 kW =	> 234727	kW	0 kW => 0	kw ;	08:10: 30/01/2
8°-	31025 KW 86,7 *0]	24 kW =>	234727			sov			No.	ord/Picardie 75863 kW =	> 234727	kW		.w	08:10: 30/01/2
9.	3025 KW 60.7 *0]	2939 KW 63.0*C	1549 IN 839 -0	1989 KW 84.0					THE SAME	75863 kW =	> 234727	kW		,	08:10: 30/01/2
	1000 LW 80.7 10	3E)	1549 LW 53 + -0	1900 NW 64.0		.w		PH.	IXES IW	75863 kW =	> 234727	kW		,	08:10: 30/01/2
	2013 NW 80.5 °C	1000 NW 80 E TO	1160 NW 87.1 0	1999 NW 84.9 1999 NW 81.9	3 3332 1W 80 4 3	NV		PH.	PROFESSION	75863 kW = 748 768 768 768 768 768 768 768 768 768 76	> 234727		0 10 10 10 10 75.4		08:10: 30/01/2
····	2012 NW 62 6 G	38 38	1100 1W 1300 0 1100 1W 17.1 0 1100 1W 17.1 0	1999 NW 84.9 1999 NW 81.9	0 000 000 000 000 000 000 000 000 000	NOV		CY.		75863 kW =	> 234727	kW	10 10 10 10 71 A		08:10: 30/01/2
····	1109 NW 86.7 '0] 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0	1995 LW 88.8 TO	1984 NW 83 9 **********************************	1000 NW 01.0	C 2005 AW 50 7 7	9 (858 SW 85.8)		CY.	PRODUCTION OF THE PRODUCTION O	75863 kW = 74810 mms w /48	> 234727	G DOS DW 79	13 10 1316 MW 75.8	0 0077 000 61 8 7 9	30/01/2
····	1109 NW 86.7 '0] 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0	1995 LW 98.8 TO	1984 NW 83 9 **********************************	1999 NW 54.00 1999 NW 61.00 1999 NW 61.00 1999 NW 63.00 1990 NW	0 000 000 000 000 000 000 000 000 000]	PH ·	HEED HAVE	75863 kW =	> 234727	C SON W FO	2 10 10 10 10 10 10 10 10 10 10 10 10 10		30/01/2
····	1109 NW 86.7 '0] 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0	1995 LW 88.8 TO	1984 NW 83 9 *0	1000 NW 01.0	C 2005 AW 50 7 7	9 (858 SW 85.8)]	PH ·	HERE DAY	75863 kW = 758 kW 7	234727 10 10 10 10 10 10 10 10 10 10 10 10 10 1	C SSSSSSSSS	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		30/01/2
ži 	1109 NW 86.7 '0] 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0	1995 LW 88.8 TO	1984 NW 83 9 *0	1000 NW 01.0	C 2005 AW 50 7 7	9 (858 SW 85.8)		CV SO	HOD IN	75863 kW = 728 cm	> 234727	G COMPANY OF	10 10 10 10 74 4 10 10 10 10 10 77 4 10 10 10 10 10 10 10 10 10 10 10 10 10 1		08:10: 30/01/2
····	1109 NW 86.7 '0] 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0	1995 LW 88.8 TO	1984 NW 83 9 *0	1000 NW 01.0	C 2005 AW 50 7 7	9 (858 SW 85.8)]	CV SO	HOS INV	7/3 10 000 107 7/3 10 000 10	2 234727 2 1111 1W 76.1 2 1111 W 76.1 2 1111 W 76.1 3 1111 W 76.1 3 1111 W 76.1 3 1111 W 76.1 3 1111 W 76.1	C SSSSSSSSS	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		30/01/2
····	1109 NW 86.7 '0] 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0 1109 NW 80.8 '0	1995 LW 88.8 TO	1984 NW 83 9 *0	1000 NW 01.0	C 2005 AW 50 7 7	9 (858 SW 85.8)	·]	PH ·	PROPERTY OF THE PROPERTY OF TH	75863 kW = 728 cm	> 234727 10 10 10 10 10 10 10	G 200 MW 27	A STATE OF THE STA		30/01/2

Our skills

Maintenance


Predictive, preventive and curative maintenance, including blades and 20kV grid




Expertise

Technical support and R&D

Wind / Acoustic / TV / GIS / SCADA-Automation / Computer science / Mechanical and Electrical engineering







Our forecasting experience

2007

Benchmark to find a provider
 About 20 companies was contacted and 10 were tested



2008

- Establishing a supply forecasts with a first provider
- 10 wind farm.
- 4 times daily as an archive on an htp server containing one csv file for each wind farm
- Forecast each 15 min
- Deadline = 6 days
- NMAE between 6 and 26 % with an average on 12% for the first 48 hours

2012





Setting up a run WRF in all our wind farm.

- Forecast each 10 min
- Deadline = 8 days
- NMAE between 4 and 45 % with an average on 16% for the first 48 hours



Our forecasting experience

2015



New benchmark provider and Change

- 10 zones → 22 wind farm.
- 1 time daily as an archive on csv file for each zone by mail
- Forecast each hour
- Deadline = 10 days
- NMAE between 6 and 30 % with an average on 12% for the first 48 hours

What kind of use:

R & D project for grid integration Maintenance Managing budgets



Our feedback




- Maintain an efficient model can be costly
- Some wind farm are hard to predict

	Provider1	Provider2	Provider3
WF1	9,16%	11,33%	11,04%
WF2	6,64%	7,95%	8,85%

- An interface is important for our use




Friday the 27th May: forecast for all turbines



<u>It's May → Not a lot of wind so not a lot of production</u>




Friday the 27th may: forecast of wind for turbines of the North



For monday 30th May: expected wind at 6m/s → Blades repairs are allowed.




Monday the 30th May: forecast for all turbines



A forecast within 1GWh (858 MWh) become a forecast almost 3GWh (2941 MWh) ? !!!



Monday the 30th May: forecast of wind for turbines of the North



Peaks at 10m/s (against 6m/s) ?!!! Blades repairs are impossible



What's happen?



Unclear at know

Some assumptions:


- Gusty winds?
- Unexpected phenomenon?



9

Other types of error

Comparaison des données réclies et prévues entre le 01/10/15 et le 31/10/15 pour un parc



time shift



Our wishes



A good interface for our special use

Ever more precice forecast

At least: better indicators of uncertainty



Future perspectives



Development of advances forecasting models

- Power production forecasts currently in use for scheduling maintenance works in particular
- Future use : Production/consumption forecasting for optimazed integration in network : overload forecasting

Maia Eolis is involved in research project « FOREWER »

- In association with RTE, EDF, Reasearch Labs and universities
- Development of advanced short term & seasonal forecasting models for wind resource/power output
- Focus on risks
- Synergy between statistical and probabilistic forecasting methods







Thank you!

Questions?

sguignard@maiaeolis.fr

